

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01/ACDWS&S/pdt

Dated: 20/08/2026

It is certified that an inspection team headed by S. Naga Bharath Reddy, Assistant Engineer (Name of the Officer with designation) from Rural water supply & Sanitation department PHED inspected the VAAGDEVI HIGH SCHOOL, H.NO 3/28, NARASIMHAPURAM, PEDDASETTIPALLE (V), PRODDATUR, Y.S.R. DISTRICT, ANDHRA PRADESH - 516360 (Name and Address of the School) on 20/08/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 01 dated 20/08/2026 of Water quality monitoring Sub-Division laboratory, RWS&S Dept (PHED Lab) certified that the VAAGDEVI HIGH SCHOOL, H.NO 3/28, NARASIMHAPURAM, PEDDASETTIPALLE (V), PRODDATUR, Y.S.R. DISTRICT, ANDHRA PRADESH - 516360 (Name and Address of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 19/08/2027

Signature with Seal: AE, RWS & S Proddatur (M)

Name: S. Naga Bharath Reddy

Designation: AE/ RWS & S / Proddatur mandal

Name & Address of the Office / Department

: 01 DCE RWS&S Sub-Div Proddatur.

To,


VAAGDEVI HIGH SCHOOL, H.NO.3/28,

NARASIMHAPURAM, PEDDASETTIPALLE (V),

PRODDATUR, Y.S.R. District, Andhra Pradesh - 516360

(Name & Address of the Institution)

Government of Andhra Pradesh					
RURAL WATER SUPPLY & SANITATION DEPARTMENT					
WATER QUALITY MONITORING SUB DIVISION LEVEL LABORATORY					
JAMMALAMADUGU-516434					
No. 01 WATER QUALITY REPORT					
Date of Collection :		20-08-2026	Date of Report		20-08-2026
Mandal :		Proddutur	Name of the Habitation :		Peddasettypalli
Name of G.P :		Narasimhapuram	Location :		Vaagdevi High School
REFERENCE NO :		869/26	Source of Water :		R.O Water
S.No.	Test Parameters	Pt-Co units	Standards of Physical & Chemical		Result
			Highest desirable Level	Maxium permissible level	
1	Colour	Pt-Co units	5.0	15.0	0
2	Turbidity	NTU	1.0	5.0	0
3	pH		6.5-8.5	No relaxation	6.55
4	EC	Micromous			117.6
5	Total Dissolved Solids	mg./lit.	500	2000	75.8
6	Total Alkanity (as Caco3)	mg./lit.	200	600	23
7	Total Hardness (as Caco3)	mg./lit.	200	600	7
8	Calcium(as Ca++)	mg./lit.	75	200	1.6
9	Magnesium (as Mg ++)	mg./lit.	30	100	0.7
10	Choloride (as Cl -)	mg./lit.	250	1000	20
11	Fluoride (as F-)	mg./lit.	1	1.5	0.19
12	Nitrate (as No3-)	mg./lit.	45	No relaxation	23.1
13	Sulfate (as So4 --)	mg./lit.	200	400	4
14	Iron (as Fe)	mg./lit.	0.3	1	0.04
Remarks		The above sample is Potable			


 Lab Chemist/Microbiologist
 RWS&S Sub Division Jammalamadugu.

Chemist/Microbiologist
WQM LABORATORY
 R.W.S. & S Sub Division
 JAMMALAMADUGU